

לפיילו אש - כל הפתרונות ל - הגנת אש על קונסטרוקציית פלדה

ביצועים מוכחים, עלות נמוכה, יישום מהיר ויעיל, מאושר ומוכר ע"י מיטב יועצי הבטיחות ונציבות הכבאות.



לפרטים נוספים בקרו באתר החברה בכתובת www.pilo-esh.co.il או במשרדנו בטלפון 03.9222113



Certificate No: FRSP438/370-120

This certifies that the products below,

Phoenix 370-120

manufactured by

Phoenix Fire Technologies (UK) Ltd

**Tower Works
Kestor Street
Bolton BL2 2AL
United Kingdom**

Satisfies the requirements of IFCC scheme SDP 012 for Reactive Coatings for Structural Steelwork. This includes the testing of products, the inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and thickness for various steel sections to achieve periods up to **180 minutes** fire resistance to **BS476: Part 21: 1987** are detailed in the following schedule. Full details regarding the scope of approval, including application of the product are given in **WF Assessment Report No. 335158 issue 2**.

The certificate remains valid subject to satisfactory annual surveillance of factory production control by IFC Certification. The reader should contact IFC Certification or refer to www.ifccertification.com to validate its status.



First Issued: 21 June 2012
Reissued: 28 July 2017
Revised: 20 March 2018
Valid to: 20 June 2022
Issue No: 5



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

Table 1: Protection to I-Section Beams

Page 1 of 32